

PDW INOP
Dataset 09.07.2017 1315hrs

vvlCurrentStatus	county	facilityName
DESTROYED	Aransas	ALTON THEISS SUBDI...
INOP	Brazoria	APACHELAND MOBIL...
	Calhoun	BAREFOOT RV PARK
	Fort Bend	BARLOW LAKE ESTAT...
	Hardin	BENTWOOD ESTATE...
	Harris	BIG THICKET LAKE ES...
	Jefferson	BRAZOS RIVER CLUB

Total									52
vvlCurrentStatus	county	ID	facilityName	populationServed	assessmentDate	comments_Secord	POC Name:	contact number	est time fully restore
DESTROYED	Brazoria	200278	BRAZOS RIVER CLUB	111	01-Sep-17	Pressure Tank Broken. There was no water at all and All customers already evacuated; therefore, no need to issue BWN.	Bill Homburg	979-900-2029	Weeks
DESTROYED	Brazoria	200401	KEY LARGO UTILITIES	28	30-Aug-17	Received an Initial Assessment Form for system from Mike Howell. Mike was contacted by Kyle Comee at 281-546-7944 who stated the system has one well and all electrical components have washed away. System is out of water and requesting assistance. Called M	Kyle Comee	281-546-7944	Unknown
INOP	Harris	1012806	ALTON THEISS SUBDIVISION	45	02-Sep-17	WTP not operational, significant damage.	Scot Foltz		Unknown
INOP	Harris	1010085	APACHELAND MOBILE HOME SUBDIVISION	177	31-Aug-17	#16 Follow up in 3-5 days #17 Entire system under potentially 4 feet of water. There isn't access to the system.	Josh McKethan	281-813-2987	Unknown
INOP	Harris	1013459	BAREFOOT RV PARK	36	04-Sep-17	System was wiped out; pressure tanks floated away along river; all piping gone, and power poles were snapped in half. System is inoperable. Contact not sure if system will operate again since it is a small MHP with low number of connection versus the da	Harrison Williams	832-534-8545	Months
INOP	Tyler	2290015	BARLOW LAKE ESTATES	67	01-Sep-17	This water system is located in a low lying area on the banks of the Neches River, which is at major flood stage, and has overflowed out of the banks. The water system is completely flooded and inaccessible. Drinking water is currently available at Town	Stonewall Jackson	936-327-1896	Unknown
INOP	Harris	1011828	BENTWOOD ESTATES MHP	135	05-Sep-17	16. ASAP	Tracy Ragsdale	713-823-3653	Days
INOP	Liberty	1460025	BIG THICKET LAKE ESTATES 1	228	02-Sep-17	Boyd McDaniel is not available the EC is Phillip Everett and he does not want to be bothered anymore. See 1460011	Boyd McDaniel	936-327-3107	
INOP	Orange	1810178	CAPRI AND GALL STREETS	50	05-Sep-17	The water system is under water and not operational.	Melvin Block	409-454-7313	Weeks
INOP	Jefferson	1230020	CARDINAL MEADOWS IMPROVEMENT DISTRICT	154	01-Sep-17	Purchase water system. Area is still flooded, but the water is receding unable to reach the plant. No service, no pressure. Customers are still evacuated at this time,	Charlie Adams	409-673-7091	Unknown

PDW INOP
Dataset 09.07.2017 1315hrs

vvICurrentStatus	county	ID	facilityName	populationServed	assessmentDate	comments_Second	POC Name:	contact number	est time fully restore
INOP	Brazoria	200001	CITY OF ALVIN	24000	31-Aug-17	One GW Plant is down, it is underwater = snyder plant (TP1133)+ well (g0200001 B) Won't be able to assess damage until utility water recedes Contact info for Brandon Moody, mobile 832 -398-0180 Backup contact: Brian Smith, Director of Public Services,	Brandon Moody	281-585-7155	
INOP	Jefferson	1230049	CITY OF BEVIL OAKS	1274	01-Sep-17	2. Area under mandatory evacuation per system contact. Contact unable to get in to area to view extent of damage. 3. Area under mandatory evacuation per system contact. Contact unable to get into area to view extent of damage. 7. Area under mandatory ev	Charlie Adams	409-782-4588	Unknown
INOP	Liberty	1460037	CITY OF DAYTON LAKES	85	04-Sep-17	She will send a list, but she said the entire system is under water.	CHARBONNEAU, ALICIA	936-402-6765	
INOP	Orange	1810139	CITY OF ROSE CITY	590	06-Sep-17	Surface water treatment plant flooded. Four feet of water remaining in plant. Lab, pumps, chemical feed, equipment, all inundated with flood water. SWMOR and lead copper question referred to Austin TCEQ	Janice Ratcliff	409-782-3927	Months
INOP	Aransas	40003	COPANO COVE SUBDIVISION	1446	04-Sep-17	purchase water system only has distribution system. No water plant, not treatment facilities. Water from city of rockport intermittent. Experiencing numerous line breaks in system and at customer connections. having difficulties locating meter boxes under d	Richard Kent	361-790-4750	Unknown
INOP	Aransas	40029	COPANO RIDGE SUBDIVISION	798	04-Sep-17	purchase water system only has distribution system. No water plant, not treatment facilities. Water from city of rockport intermittent. Experiencing numerous line breaks in system and at customer connections. Having difficulties locating meter boxes under d	Richard Kent	361-790-4750	
INOP	Orange	1810123	CORBETT WATER SYSTEM 1	79	02-Sep-17	No damage. No power. Boil water notice when power restored.	Kelly Brewer	409-791-2104	Unknown
INOP	Hardin	1000061	COUNTRYWOOD WATER SYSTEM	456	02-Sep-17	Facility flooded. Will need to replace booster pumps, controls OK. No power, no bottled water, not accessible. No generator. Will issue boil water notice.	Kelly Brewer	409-791-2104	Unknown
INOP	Harris	1010919	CYPRESS FOREST PUD	6387	05-Sep-17	info from spreadsheet	Greg Camp	281-870-3949	Unknown
INOP	Liberty	1460109	CYPRESS LAKES WATER SYSTEM	315	02-Sep-17	14 ft of water hard to assess the damage. hydronic and ground storage tank are ripped off the pipes and are laying in other parts of the system. destroyed public water system, the waste water system is not destroyed. North side of the public water sys	Roy Boddie	281-806-1590	Months

PDW INOP
Dataset 09.07.2017 1315hrs

vvICurrentStatus	county	ID	facilityName	populationServed	assessmentDate	comments_Second	POC Name:	contact number	est time fully restore
INOP	Hardin	1000065	DAIRYLAND HEIGHTS WATER SYSTEM	103	02-Sep-17	Accessible no damage. No power. Once restoed boil water needed. No generator. Waiting for power.	Kelly Brewer	409-791-2104	Unknown
INOP	Hardin	1000016	HARDIN COUNTY WCID 1	1179	02-Sep-17		Ayo Falade		NA
INOP	Harris	1011162	HARRIS COUNTY MUD 33	5178	04-Sep-17	Waiting for final assessments on damages	RICHARD CLARK	281-788-4650	Unknown
INOP	Harris	1013159	HUNTERS VILLAGE SUBDIVISION	90	06-Sep-17	Most recent update from Scott Fultz on 9/3: "crews working on plant" plant experineced major damage, is still inoperable and the BWN is still in effect at this time	Scott Fultz	512-990-4400	
INOP	Orange	1810059	KINARD ESTATES	233	02-Sep-17	No power, No damage. Had no calls. They cannot access to check status.	Kelly Brewer	409-791-2104	Unknown
INOP	Harris	1010494	LAKE FOREST UTILITY DISTRICT	6291	05-Sep-17	Q.13 BWN rescinded 9/1/17. Q.12. BWN issued by media release and posting signs in district Info taken from spreadsheet	Greg Camp	281-870-3949	Unknown
INOP	Liberty	1460007	LAKE LIVINGSTON BIG THICKET LAKE 2	435	29-Aug-17	John Sexton self-reported an outage for the PWS on 8/28/2017 in the SB/LGA Outage website. Q.3. Fallen trees tore out water lines. Q.7. Expect to have service restored on 8/30/2017. Q.16. Follow up on or after 8/31/2017 to check status.	Phillip Everett	936-328-2934	Days
INOP	Wilson	2470020	LAKE VALLEY WATER	456	30-Aug-17	PWS is without power. They used an auto dialer system to issue a BWN. Unsure if storage was enough to maintain pressure. A generator is scheduled for delivery this afternoon.	Billy Martin	940-445-7725	Days
INOP	Orange	1810025	LAKEVIEW ESTATES	74	05-Sep-17	Water system has lost pressure but water is not being supplied at this time because the plant is under water.	Melvin Block	409-454-7313	Unknown
INOP	Harris	1010495	MALCOMSON ROAD UTILITY DISTRICT	7245	06-Sep-17	This water system has two water plants. This evaluation is for water plant #1. It is offline waiting for repairs. Flood water entered the well vent. Well was flushed for 24 hours then super chlorinated. Bacteriological samples were good. Electrical contro	Jeff Cotton	832-467-1599	Days
INOP	Brazoria	200277	MALLARD LAKE CLUB	80	03-Sep-17	Plant not Accessible due to flooding on CR25 3,4, and 5 - Unknown 10, 11, 12, 13 - Unknown.	Jay Herben		Unknown
INOP	Jefferson	1230004	MEEKER MWD	2687	01-Sep-17	No service, no pressure. System has 2 GW plants that were both submerged in the flood waters, controls and electrical are an unknown. Board President began handing out bottled water this morning to returning customers. A generator request was submitted	Charlie Adams	409-385-0783	Weeks

PDW INOP
Dataset 09.07.2017 1315hrs

vvICurrentStatus	county	ID	facilityName	populationServed	assessmentDate	comments_Second	POC Name:	contact number	est time fully restore
INOP	Jefferson	1230086	NORTHWEST FOREST MUD	615	01-Sep-17	Purchase water system, from Beaumont. No power, no service, zero pressure. There is still flooding, but the water is receding. Customers are still evacuated.	Charlie Adams	409-385-0783	Unknown
INOP	Orange	1810179	OAK ACRES MOBILE HOME PARK	77	01-Sep-17	Residents are currently evacuated and a BWN will be in place when they get back.	Charlie Adams	409-782-4588	Days
INOP	Waller	2370005	PATTISON WSC	1461	29-Aug-17	Ms Chapa said the system is flooded and can not completely assess the level of damage. Will need follow up in one week to further assess the system's needs.	Vanessa Chapa	281-877-2612	Weeks
INOP	Montgomery	1700064	PEACH CREEK DAM and LAKE CLUB	204	03-Sep-17	#3 - The whole system (wells) completely submerged under water. #6 - No power has been restored; unable to do an assessment of system. #7 - Electric company has not provided status when power will be restored. #11 - System submerged under water.	Tom Enix	832-266-9150	Unknown
INOP	Calhoun	290028	PORT ALTO WSC	115	01-Sep-17		Randy Underwood	361-893-5934	Unknown
INOP	Hardin	1000070	RANCHLAND	42	02-Sep-17				
INOP	Harris	1011071	RIO VILLA WSC	432	05-Sep-17	11. BWN issued due to pressure loss as well as line break. dlindquist@SJRA.net 3 month supply on hand at least 14 feet.	David Lindquist	936-521-9083	Days
INOP	Brazoria	200058	RIVERSIDE ESTATES	144	03-Sep-17	No water was the reason given with for the BWN. Posted notice in the entrance. "Because the access roads to the Majority of our systems are flooded, access is not currently possible. In addition, most of these systems are in mandatory evacuation zones.	John Wittenzellner, Jr	940-483-1876	Unknown
INOP	Jefferson	1230083	SUNCHASE SUBDIVISION	104	06-Sep-17	most recent update from Scott Fultz on 9/4: "Able to access, doing damage assesment" plant is still inoperable and BWN remains in effect	Scott Fultz	512-990-4400	
INOP	Aransas	40055	SUNSET BAY	0	04-Sep-17	Power is expected to be restored by Setpember 8th. Nobody is living there now	Ryan Quigley	832-244-1750	
INOP	Brazoria	200201	TDCJ RAMSEY AREA	5119	01-Sep-17	2Q - TCDJ has evacuated these units associated with this PWS. System has been shut down since August 29. As of 9/1, they are waiting for water to recede to determine any damage before we turn system back on. 8-13Q - The TDCJ Ramsey Area serves 3 units an	TDCJ		Unknown
INOP	Fort Bend	790013	TELEVIEW TERRACE SUBDIVISION	195	03-Sep-17	All answers on the spreadsheet provided on spreadsheet are N/A and all contacts on drinking water watch have disconnected phone lines, but it is still listed as an active system. Info provided by John Wittenzellner of Utility Group of Texas in a spreadshe	John Wittenzellner Jr	940-683-1876	

PDW INOP
Dataset 09.07.2017 1315hrs

vvICurrentStatus	county	ID	facilityName	populationServed	assessmentDate	comments_Second	POC Name:	contact number	est time fully restore
INOP	Victoria	2350009	THE ESTATES OF SANDY HILLS	18	01-Sep-17	The facility does not have power. The system only serves 11 customers. The customers are not residing in the area due to damage to trailers.	Bulmaro Martinez	361-649-1979	Days
INOP	Orange	1810170	TIMER WATER SYSTEM	39	02-Sep-17	Accessible all ok. No power	Kelly Brewer	409-791-2104	Unknown
INOP	Tyler	2290043	TOWN BLUFF WATER SYSTEM	95	01-Sep-17		Stonewall Jackson	936-327-1896	Hours
INOP	Harris	1011825	WEST HARRIS COUNTY MUD 4	1611	05-Sep-17	Greg camp emailed us a spreadsheet with the info provided. Plant is currently offline, but it is unrelated to the storm.	Greg Camp	281-870-3949	NA
INOP	Hardin	1000038	WHISPERING PINES SUBDIVISION	56	02-Sep-17	Down for several days. Needs boil water notice. Needs power-no generator. Accessed 9/1/2017. Won't be back on until power is back on. No bottled water.	Kelly Brewer	409-791-2104	Unknown
INOP	Tyler	2290012	WHITE TAIL RIDGE LAKES ESTATES	227	01-Sep-17	The well and plant site is flooded so the water system officials cannot currently access the area due to road damage. This area is also experiencing a power outage, but portable generators cannot be used at this time due to the plant being not accessible.	Stonewall Jackson	936-327-1896	Days
INOP	Harris	1010920	WINDWOOD WATER SYSTEM	42	04-Sep-17	System was heavily damaged; whole control panel, booster pumps, and water well under water. The pressure tank will need to reset and wells re-chlorinated. Water well company coming out on 9/5/2017 to get it going and back on-line.	Harrison Williams	832-534-8545	Days
INOP	Orange	1810150	YEAGER ESTATES ADDITION	51	02-Sep-17	Cant access. Unsure of status. May be flooded.	Kelly Brewer	409-791-2104	Unknown
52									